



Circuit diagram

Dimensions (mm)



Allgemeine Toleranzen General tolerances Tolérances en général L + 50% - 30% C ± 20% R ± 10%

Daten (single phase) data caractéristiques

Nennstrom bei Umgebungstemp. rated current at an ambient temp. courant nominal à une température ambiante 11 A 40 °C

Nennspannung rated voltage tension nominal max. 250 V, 50/60Hz

Betriebsfrequenz operating frequency fréquence de service max. 60 Hz

Ableitstrom nominal Nominal operational leakage courant nominal Spannung P-E / Frequenz 250 VAC 50 Hz I nom. 26.7 mA

Maximaler Ableitstrom Max leakage current courant maximale de fuite Spannung P-E / Frequenz 250 VAC 50 Hz I max. 52.7 mA

DC-Widerstand DC-resistance DC-résistance @ 25 °C max. 2 x 25 mOhm

Pruefspannung 100% Schlusskontr. test voltage 100% final test tension d'essais contrôle final 100% P/N->E 2.2 kV/DC ≥ 2s P->N 1.1 kV/DC ≥ 2s

Wiederholung mit max. 80% der angegebenen Werte repetition with max. 80% of the specified values répétition avec max. 80% des valeurs spécifiques

Zulaessige Betriebstemp. temperature range gamme de température - 25°C bis/to/à + 85 °C

Klimatische Pruefklasse climatic test class classe d'essais climatique 25/085/21 (IEC/CEI 60068-1)

FS33221-11-07 122370 F

Zusatzangaben additional information informations supplémentaires

Vergussmasse potting compound matière de moulage Polyurethane

Gewicht weight poids 490 g

Pruefzeichen approvals homologations CSA / C-US UL 1283 C 22.2 No.8 CSA C 22.2 No.8 UL UL 1283 ENEC IEC/EN 60939 VDE

Zusätzliche Angaben: Additional remarks: Nidec Control Techniques Part No. 4200-1000

Fuer Masse ohne Toleranz for dimensions without tolerance pour mesure sans tolérance ISO2768-m/EN22768-m

Datenblatt (single phase) data sheet fiche technique

F	20003551, Add customer name Nidec Control...	22.02.2018		%	A3	created	22.02.2018	LAMASR
E	20003139, Change CT label from Emerson to Nidec	18.09.2017				checked	22.02.2018	LAMEYO
D	20001142, CE-Declaration for FS3322x-Series	25.01.2016				released	22.02.2018	LAMEYO
C	150631, Add c-UR-us mark (No.7)	23.09.2014	projection	scale	format	status	date	user
B	50004669, add customer number	26.11.2013						
A		11.11.2013	FS33221-11-07 project					
rev.	modification / report no.	date	813731 mat. number					
We reserve all rights in this document and in the information contained therein. Passing on and/or copying of this document, use and/or communication of its content is not permitted without authorization			DSH	122370	F	1 / 1		
Template: SPC 144312A			doc. type	doc. number	doc. rev.	page		